



Standard Specification for Fuel Oils¹

This standard is issued under the fixed designation D 396; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This specification (Note 1) covers grades of fuel oil intended for use in various types of fuel-oil-burning equipment under various climatic and operating conditions. These grades are described as follows:

1.1.1 Grades 1, 1 Low Sulfur, 2, and 2 Low Sulfur are middle distillate fuels for use in domestic and small industrial burners. Grades 1 and 1 Low Sulfur are particularly adapted to vaporizing type burners or where storage conditions require low pour point fuel.

1.1.2 Grades 4 (Light) and 4 are heavy distillate fuels or distillate/residual fuel blends used in commercial/industrial burners equipped for this viscosity range.

1.1.3 Grades 5 (Light), 5 (Heavy), and 6 are residual fuels of increasing viscosity and boiling range, used in industrial burners. Preheating is usually required for handling and proper atomization.

NOTE 1—For information on the significance of the terminology and test methods used in this specification, see Appendix X1.

NOTE 2—A more detailed description of the grades of fuel oils is given in X1.3.

1.2 This specification is for the use of purchasing agencies in formulating specifications to be included in contracts for purchases of fuel oils and for the guidance of consumers of fuel oils in the selection of the grades most suitable for their needs.

1.3 Nothing in this specification shall preclude observance of federal, state, or local regulations which can be more restrictive.

1.4 All values are stated in SI units and are regarded as standard.

NOTE 3—The generation and dissipation of static electricity can create problems in the handling of distillate burner fuel oils. For more information on the subject, see Guide D 4865.

2. Referenced Documents

2.1 ASTM Standards:

¹ This specification is under the jurisdiction of ASTM Committee D02 on Petroleum Products and Lubricants and is the direct responsibility of Subcommittee D02.E0.01 on Burner Fuels.

Current edition approved Nov. 10, 2002. Published November 2002. Originally published as D 396–34T. Last previous edition D 396–02.

- D 56 Test Method for Flash Point by Tag Closed Tester²
- D 86 Test Method for Distillation of Petroleum Products at Atmospheric Pressure²
- D 93 Test Methods for Flash Point by Pensky-Martens Closed Cup Tester²
- D 95 Test Method for Water in Petroleum Products and Bituminous Materials by Distillation²
- D 97 Test Method for Pour Point of Petroleum Products²
- D 129 Test Method for Sulfur in Petroleum Products (General Bomb Method)²
- D 130 Test Method for Detection of Copper Corrosion from Petroleum Products by the Copper Strip Tarnish Test²
- D 445 Test Method for Kinematic Viscosity of Transparent and Opaque Liquids²
- D 473 Test Method for Sediment in Crude Oils and Fuel Oils by the Extraction Method²
- D 482 Test Method for Ash from Petroleum Products²
- D 524 Test Method for Ramsbottom Carbon Residue of Petroleum Products²
- D 975 Specification for Diesel Fuel Oils²
- D 1266 Test Method for Sulfur in Petroleum Products (Lamp Method)²
- D 1298 Test Method for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method²
- D 1552 Test Method for Sulfur in Petroleum Products (High-Temperature Method)²
- D 2500 Test Method for Cloud Point of Petroleum Products²
- D 2622 Test Method for Sulfur in Petroleum Products by Wavelength Dispersive X-Ray Fluorescence Spectrometry²
- D 2709 Test Method for Water and Sediment in Middle Distillate Fuels by Centrifuge²
- D 3245 Test Method for Pumpability of Industrial Fuel Oils³
- D 3828 Test Methods for Flash Point by Small Scale Closed Tester³
- D 4052 Test Method for Density and Relative Density of Liquids by Digital Density Meter³

² Annual Book of ASTM Standards, Vol 05.01.

³ Annual Book of ASTM Standards, Vol 05.02.

TABLE 1 Detailed Requirements for Fuel Oils^A

Property	ASTM Test Method ^B	No. 1 Low Sulfur ^C	No. 1 ^C	No. 2 Low Sulfur ^C	No. 2 ^C	Grade No. 4 (Light) ^C	No. 4	No. 5 (Light)	No. 5 (Heavy)	No. 6
Flash Point °C, min	D 93 – Proc. A	38	38	38	38	38
	D 93 – Proc. B	55	55	55	60
Water and sediment, % vol, max	D 2709	0.05	0.05	0.05	0.05
	D 95 + D 473	(0.50) ^D	(0.50) ^D	(1.00) ^D	(1.00) ^D	(2.00) ^D
Distillation temperature °C	D 86									
10 % volume recovered, max		215	215
90 % volume recovered, min		282	282
90 % vol recovered, max		288	288	338	338
Kinematic viscosity at 40°C, mm ² /s	D 445									
		min	1.3	1.3	1.9	1.9	1.9	>5.5
max		2.1	2.1	3.4	3.4	5.5	24.0 ^E
Kinematic viscosity at 100°C, mm ² /s	D 445									
		min	5.0	9.0	15.0
max		8.9 ^E	14.9 ^E	50.0 ^E	
Ramsbottom carbon residue on 10 % distillation residue % mass, max	D 524	0.15	0.15	0.35	0.35
Ash, % mass, max	D 482	0.05	0.10	0.15	0.15	...
Sulfur, % mass max ^F	D 129	...	0.50	...	0.50
	D 2622	0.05	...	0.05
Copper strip corrosion rating, max, 3 h at 50°C	D 130	No. 3	No. 3	No. 3	No. 3
Density at 15°C, kg/m ³	D 1298									
		min	>876 ^G
max		850	850	876	876	
Pour Point °C, max ^H	D 97	-18	-18	-6	-6	-6	-6

^A It is the intent of these classifications that failure to meet any requirement of a given grade does not automatically place an oil in the next lower grade unless in fact it meets all requirements of the lower grade. However, to meet special operating conditions, modifications of individual limiting requirements may be agreed upon among the purchaser, seller, and manufacturer.

^B The test methods indicated are the approved referee methods. Other acceptable methods are indicated in Section 2 and 5.1.

^C Under United States regulations, Grades No. 1, No. 1 Low Sulfur, No. 2, No. 2 Low Sulfur, and No. 4 (Light) are required by 40 CFR Part 80 to contain a sufficient amount of the dye Solvent Red 164 so its presence is visually apparent. At or beyond terminal storage tanks, they are required by 26 CFR Part 48 to contain the dye Solvent Red 164 at a concentration spectrally equivalent to 3.9 lb per thousand barrels of the solid dye standard Solvent Red 26.

^D The amount of water by distillation by Test Method D 95 plus the sediment by extraction by Test Method D 473 shall not exceed the value shown in the table. For Grade No. 6 fuel oil, the amount of sediment by extraction shall not exceed 0.50 mass %, and a deduction in quantity shall be made for all water and sediment in excess of 1.0 mass %.

^E Where low sulfur fuel oil is required, fuel oil falling in the viscosity range of a lower numbered grade down to and including No. 4 can be supplied by agreement between the purchaser and supplier. The viscosity range of the initial shipment shall be identified and advance notice shall be required when changing from one viscosity range to another. This notice shall be in sufficient time to permit the user to make the necessary adjustments.

^F Other sulfur limits may apply in selected areas in the United States and in other countries.

^G This limit ensures a minimum heating value and also prevents misrepresentation and misapplication of this product as Grade No. 2.

^H Lower or higher pour points can be specified whenever required by conditions of storage or use. When a pour point less than -18°C is specified, the minimum viscosity at 40°C for grade No. 2 shall be 1.7 mm²/s and the minimum 90 % recovered temperature shall be waived.

^I Where low sulfur fuel oil is required, Grade No. 6 fuel oil will be classified as Low Pour (+15°C max) or High Pour (no max). Low Pour fuel oil should be used unless tanks and lines are heated.

D 4057 Practice for Manual Sampling of Petroleum and Petroleum Products³

D 4294 Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry³

D 4865 Guide for Generation and Dissipation of Static Electricity in Petroleum Fuel Systems³

D 5453 Test Method for Determination of Total Sulfur in Light Hydrocarbons, Motor Fuels and Oils by Ultraviolet Fluorescence⁴

D 5949 Test Method for Pour Point of Petroleum Products (Automatic Pressure Pulsing Method)⁴

D 5950 Test Method for Pour Point of Petroleum Products (Automatic Tilt Method)⁴

D 5985 Test Method for Pour Point of Petroleum Products (Rotational Method)⁴

D 6469 Guide to Microbial Contamination in Fuels and Fuel Systems⁵

2.2 Other Documents:⁶

26 CFR Part 48 Diesel Fuel Excise Tax; Dye Color and Concentration

40 CFR Part 80 Regulation of Fuel and Fuel Additives

3. General Requirements

3.1 The grades of fuel oil specified herein shall be homogeneous hydrocarbon oils, free from inorganic acid, and free from excessive amounts of solid or fibrous foreign matter.

3.2 All grades containing residual components shall remain uniform in normal storage and not separate by gravity into light and heavy oil components outside the viscosity limits for the grade.

4. Detailed Requirements

4.1 The various grades of fuel oil shall conform to the limiting requirements shown in Table 1. A representative sample shall be taken for testing in accordance with Practice D 4057.

⁴ Annual Book of ASTM Standards, Vol 05.03.

⁵ Annual Book of ASTM Standards, Vol 05.04.

⁶ Available from U.S. Government Printing Office, Superintendent of Documents, 732 N. Capitol St., NW, Mail Stop: SDE, Washington, DC 20401.

4.2 Modifications of limiting requirements to meet special operating conditions agreed upon between the purchaser, the seller, and the supplier shall fall within limits specified for each grade, except as stated in supplementary footnotes for Table 1.

5. Test Methods

5.1 The requirements enumerated in this specification shall be determined in accordance with the following ASTM test methods,⁷ except as may be required under 5.1.1.

5.1.1 *Flash Point*—Test Method D 93 (Procedure A) for Grades No. 1, No. 1 Low Sulfur, No. 2, No. 2 Low Sulfur, and No. 4 (Light), and Test Method D 93 (Procedure B) for Grades No. 4, No. 5 (Light), No. 5 (Heavy), and No. 6, except where other methods are prescribed by law. For Grades No. 1, No. 1 Low Sulfur, No. 2, No. 2 Low Sulfur, and No. 4 (Light), Test Method D 3828 may be used as an alternate with the same limits. For Grades No. 1, No. 1 Low Sulfur, No. 2, and No. 2 Low Sulfur, Test Method D 56 may be used as an alternate with the same limits, provided the flash point is below 93°C and the viscosity is below 5.5 mm²/s at 40°C. This test method will give slightly lower values. In cases of dispute, Test Method D 93, with the appropriate procedure, shall be used as the referee method.

5.1.2 *Pour Point*—Test Method D 97. For all grades, the automatic Test Methods D 5949, D 5950, and D 5985 can be used as alternates with the same limits. In case of dispute, Test Method D 97 shall be used as the referee method. Alternative test methods that indicate flow point properties can be used for

low sulfur residual fuels by agreement between purchaser and supplier.

5.1.3 *Water and Sediment*—The water and sediment in Grade Nos. 1 and 2 shall be determined in accordance with Test Method D 2709 and in Grade Nos. 4, 5, and 6 by Test Method D 95 and Test Method D 473. A density of 1.0 kg/L shall be used for the Test Method D 95 water.

5.1.4 *Carbon Residue*—Test Method D 524.

5.1.5 *Ash*—Test Method D 482.

5.1.6 *Distillation*—Distillation of Grade No. 1 and No. 2 oils shall be determined in accordance with Test Method D 86.

5.1.7 *Viscosity*—Viscosity shall be determined in accordance with Test Method D 445.

5.1.8 *Density*—Practice D 1298. Test Method D 4052 can be used as an alternate with the same limits. In case of dispute, Practice D 1298 shall be used as the referee method.

5.1.9 *Corrosion*—Test Method D 130, 3 h test at 50°C.

5.1.10 *Sulfur*—Test Method D 129 for Grades 1, 2, 4, 5, and 6 and Test Method D 2622 for Grades 1 Low Sulfur and 2 Low Sulfur. Test Methods D 1552, D 2622, and D 4294 can also be used for all grades. In addition, Test Method D 1266 can be used for Grades 1 and 1 Low Sulfur, but only with samples having sulfur contents of 0.4 mass % and less (down to 0.01 %). Test Method D 5453 can be used for Grades 1 and 2 fuel oils, but only with samples having sulfur contents of 0.8 mass % and less (down to 0.001 %). In case of dispute, Test Method D 129 is the referee test method for Grades 1, 2, 4, 5, and 6 of this specification and Test Method D 2622 is the referee test method for Grades 1 Low Sulfur and 2 Low Sulfur.

⁷ For information on the precision of the ASTM test methods for fuel oils refer to “An Evaluation of Methods for Determination of Sulfur in Fuel Oils” by A. R. Crawford, Esso Mathematics and Systems Inc. and G. V. Dyroff, Esso Research and Engineering Co., 1969. This document is available from the Publications Section, API Library, American Petroleum Institute, 1220 L St., NW, Washington, DC 20005.

6. Keywords

6.1 burner fuels; fuel oils; furnace oils; petroleum and petroleum products

APPENDIX

(Nonmandatory Information)

X1. SIGNIFICANCE OF ASTM SPECIFICATION FOR FUEL OILS

X1.1 Scope

X1.1.1 This specification divides fuel oils into grades based upon the types of burners for which they are suitable. It places limiting values on several of the properties of the oils in each grade. The properties selected for limitation are those that are believed to be of the greatest significance in determining the performance characteristics of the oils in the types of burners in which they are most commonly used.

X1.2 Classes

X1.2.1 Because of the methods employed in their production, fuel oils fall into two broad classifications: distillates and residuals. The distillates consist of overhead or distilled fractions. The residuals are bottoms remaining from the distillation, or blends of these bottoms with distillates. In this specification, Grades No. 1 and No. 2 are distillates and the

grades from No. 4 to No. 6 are usually residual, although some heavy distillates can be sold as Grade No. 4.

X1.3 Grades

X1.3.1 *Grades No. 1 and No. 1 Low Sulfur* are middle distillates intended for use in burners of the vaporizing type in which the oil is converted to a vapor by contact with a heated surface or by radiation. High volatility is necessary to ensure that evaporation proceeds with a minimum of residue. The low sulfur grade may be specified by federal, state, or local regulations and can result in reduced deposits on ferrous heat exchanger surfaces compared to Grade No. 1 when burned under similar conditions.

X1.3.2 *Grades No. 2 and No. 2 Low Sulfur* are middle distillates somewhat heavier than grades No. 1 and No. 1 Low Sulfur. They are intended for use in atomizing type burners

which spray the oil into a combustion chamber where the tiny droplets burn while in suspension. These grades of oil are used in most domestic burners and in many medium capacity commercial-industrial burners where ease of handling and ready availability sometimes justify higher cost over the residual fuels. The low sulfur grade may be specified by federal, state, or local regulations and can result in reduced deposits on ferrous heat exchanger surfaces compared to Grade No. 2 when burned under similar conditions.

X1.3.3 *Grade No. 4 (Light)* is a heavy distillate fuel or distillate/residual fuel blend meeting the specification viscosity range. It is intended for use both in pressure-atomizing commercial-industrial burners not requiring higher cost distillates and in burners equipped to atomize oils of higher viscosity. Its permissible viscosity range allows it to be pumped and atomized at relatively low-storage temperatures.

X1.3.4 *Grade No. 4* is usually a heavy distillate/residual fuel blend but can be a heavy distillate fuel meeting the specification viscosity range. It is intended for use in burners equipped with devices that atomize oils of higher viscosity than domestic burners can handle. Its permissible viscosity range allows it to be pumped and atomized at relatively low storage temperatures. Thus, in all but extremely cold weather it requires no preheating for handling.

X1.3.5 *Grade No. 5 (Light)* is residual fuel of intermediate viscosity for burners capable of handling fuel more viscous than grade No. 4 without preheating. Preheating may be necessary in some types of equipment for burning and in colder climates for handling.

X1.3.6 *Grade No. 5 (Heavy)* is a residual fuel more viscous than Grade No. 5 (Light) and is intended for use in similar service. Preheating may be necessary in some types of equipment for burning and in colder climates for handling.

X1.3.7 *Grade No. 6*, sometimes referred to as Bunker C, is a high-viscosity oil used mostly in commercial and industrial heating. It requires preheating in the storage tank to permit pumping, and additional preheating at the burner to permit atomizing. The extra equipment and maintenance required to handle this fuel usually preclude its use in small installations.

X1.3.8 Residual fuel oil supplied to meet regulations requiring low sulfur content can differ from the grade previously supplied. It may be lower in viscosity (and fall into a different grade number). If it must be fluid at a given temperature, Test Method D 97 need not accurately reflect the pour point which can be expected after a period of storage. It is suggested that the purchaser and supplier discuss the proper handling and operating techniques for a given low-sulfur residual fuel oil in the installation where it is to be used.

X1.4 Significance of Test Methods

X1.4.1 The significance of the properties of fuel oil on which limitations are placed by the specification is as follows:

X1.4.1.1 *Flash Point*—The flash point of a fuel oil is an indication of the maximum temperature at which it can be stored and handled without serious fire hazard. The minimum permissible flash point is usually regulated by federal, state, or municipal laws and is based on accepted practice in handling and use.

X1.4.1.2 *Reduced Temperature Properties*—The fuel's

cloud and pour points are good measures for determining low temperature operability with a batch of fuel oil. It is especially important to consider these fuel properties if the heating oil will be subjected to low ambient temperatures at time of use. Fuel temperatures can fluctuate markedly in small, residential, outdoor, above ground tanks compared with indoor, basement tanks, or underground tanks. A decrease or stoppage of fuel flow can occur in small transfer lines used for residential heating applications because the fuel line temperature will fluctuate with ambient temperature faster than will bulk tank contents. Fuel oils purchased during the summer, but not used until the cold heating season arrives, can be a serious source of problems. This is because when these fuels are produced they are intended for use during the warm season and thus typically have higher cloud and pour points than fuels produced for use during the cold season. Fuels can be produced for use at low temperatures with lower cloud and pour points by blending with low paraffin fuels, such as kerosine or No. 1 fuel, and additives, or a combination thereof, to improve low temperature operability. The key to effective treatment is routine monitoring of incoming and stored fuels, and testing of the treated fuels. Although this specification only sets maximum limits for the pour point, the recommendations for cloud point of distillate fuels in Specification D 975 may be applied to heating fuels under extreme cold conditions. Some pipeline companies or local specifications have included requirements for both cloud and pour points for certain grades of fuel oil.

(1) *Pour Point*—The pour point is an indication of the lowest temperature at which a fuel oil is capable of flowing under very low forces. The pour point is prescribed in accordance with the conditions of storage and use. Higher pour point fuels are permissible where heated storage and adequate piping facilities are provided. An increase in pour point can occur when residual fuel oils are subjected to cyclic temperature variations that can occur in the course of storage or when the fuel is preheated and returned to storage tanks. To predict these properties, Test Method D 3245 may be required.

(2) *Cloud Point (Test Method D 2500)*—The cloud point defines the temperature at which a cloud or haze of wax crystals appears in the oil under prescribed test conditions which generally relates to the temperature at which wax crystals begin to precipitate from the oil in use. It is generally observed that cloud point temperature of a fuel oil is higher than its pour point by several degrees Celsius. Fuel oils stored at, or below, their cloud point temperature can have suspended wax crystals that may cause operability problems due to plugging. Examples are when fuels are pumped through small openings or passageways, that is, oil-line filters, burner nozzles, and pump strainers. The plugging is reversible when the fuel is warmed.

X1.4.1.3 *Water and Sediment*—Appreciable amounts of water and sediment in a fuel oil tend to cause fouling of facilities for handling it, and to give trouble in burner mechanisms. Sediment may accumulate in storage tanks and on filter screens or burner parts, resulting in obstruction to flow of oil from the tank to the burner. Water in distillate fuels can cause corrosion of tanks and equipment and it can cause emulsions in residual fuels.

X1.4.1.4 Carbon Residue—The carbon residue of a fuel is a measure of the carbonaceous material left after all the volatile components are vaporized in the absence of air. It is a rough approximation of the tendency of a fuel to form deposits in vaporizing burners, such as pot-type and sleeve-type burners, where the fuel is vaporized in an air-deficient atmosphere.

X1.4.1.4.1 To obtain measurable values of carbon residue in the lighter distillate fuel oils, it is necessary to distill the oil to remove 90 % of it in accordance with Section 9 of Test Method D 524, and then determine the carbon residue concentrated in the remaining 10 % bottoms.

X1.4.1.5 Ash—The amount of ash is the quantity of non-combustible material in an oil. Excessive amounts can indicate the presence of materials that cause high wear of burner pumps and valves, and contribute to deposits on boiler heating surfaces.

X1.4.1.6 Distillation—The distillation test shows the volatility of a fuel and the ease with which it can be vaporized. The test is of greater significance for oils that are to be burned in vaporizing type burners than for the atomizing type. For example, the maximum 10 % and 90 % distilled temperatures are specified for grade No. 1 fuel. The limiting 10 % value ensures easy starting in vaporizing type burners and the 90 % limit excludes heavier fractions that would be difficult to vaporize.

(1) The limits specified for grade No. 2 heating oil define a product that is acceptable for burners of the atomizing type in household heating installations. Distillation limits are not specified for fuel oils of grades Nos. 4, 5, and 6.

X1.4.1.7 Viscosity Limits for Grades Nos. 1 and 2—The viscosity of an oil is a measure of its resistance to flow. In fuel oil it is highly significant since it indicates both the relative ease with which the oil will flow or can be pumped, and the ease of atomization.

(1) Viscosity limits for No. 1 and No. 2 grades are specified to help maintain uniform fuel flow in appliances with gravity

flow, and to provide satisfactory atomization and constant flow rate through the small nozzles of household burners. For the heavier grades of industrial and bunker fuel oils, viscosity is of major importance, so that adequate preheating facilities can be provided to permit them to be pumped to the burner and to provide good atomization. However, it is equally important that the maximum viscosity under the existing conditions be such that the oil can be pumped satisfactorily from the storage tank to the preheater.

X1.4.1.8 Density—Density alone is of little significance as an indication of the burning characteristics of fuel oil. However, when used in conjunction with other properties, it is of value in mass-volume relationships and in calculating the specific energy (heating value) of an oil.

X1.4.1.9 Corrosion—The corrosion test serves to indicate the presence or absence of materials that could corrode copper, brass, and bronze components of the fuel system. This property is specified only for Nos. 1 and 2 distillate fuel oils.

X1.4.1.10 Limited sulfur content of fuel oil can be required for special uses in connection with heat treatment, nonferrous metal, glass, and ceramic furnaces or to meet federal, state, or local legislation or regulations.

X1.4.1.11 Nitrogen—Nitrogen oxide emission regulations have been imposed on certain combustion facilities as a function of fuel nitrogen content. For purposes of these regulations, distillate fuels, low nitrogen residual fuels, and high nitrogen residual fuels have been defined by their nitrogen content. Installations are required to meet different emission standards according to the classification of the fuel being used. When regulations require such a distinction to be made, fuel nitrogen specifications can be needed in the contractual agreement between the purchaser and the supplier.

X1.5 Other

X1.5.1 Microbial Contamination—Refer to Guide D 6469 for a discussion of this form of contamination.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).